

COMPLIANCE
AND
RESEARCH
SERVICES, INC.

1701 West Front Street Plainfield NJ 07063
PHONE (908) 561-1824 • FAX (908) 755-5893

August 24, 2006

Coates International, LTD
2100 Highway 34
Wall, NJ 07719-9738

Re: Nonroad Engine Certification

Dear Mr. Coates,

In regards to your current engine project, a normally aspirated 14.0 liter inline 6 cylinder fueled by natural gas powering a stationary generator, we have determined that this engine application complies with the guidance of 40 CFR 1048 "CONTROL OF EMISSIONS FROM NEW, LARGE NONROAD SPARK-IGNITION ENGINES" (Title 40 of the Code of Federal Regulations Part 1048) (http://www.access.gpo.gov/nara/cfr/waisidx_05/40cfr1048_05.htm).

As per 40 CFR 1048.5 (d), as defined in 40 CFR 1048.801¹, your stationary engines are in compliance with this part. You are further obligated to comply with 40 CFR 1048.20² (Labeling requirements) and prohibitions of 40 CFR 1068.101 restrict the use of a stationary engine.

Regards,



Mark Timko
President

¹ See attachment 1

² See attachment 2